



GEO Group Northwest, Inc.

Geotechnical Engineers, Geologists, &
Environmental Scientists

13705 Bel Red Road
Bellevue, WA 98005-4517

Phone (425) 649-8757
Fax (425) 649-8758

FIELD REPORT

Job No. G-3936	Date 8/31/2018	Page 1 of 1	Report No. 8
-------------------	-------------------	----------------	-----------------

Project Name / Location

Summit Homes, Forest Heights, Lots 4 and 5


Permit No.

Lot 22

Bill Chang from GEO Group Northwest, Inc. conducted a site visit and performed geotechnical inspection for the subgrade at Lot 22.

We observed that the excavation extended into dense native soils. Some water seepage was observed to flow into the excavation from the uphill side of the cut.

The excavation has been approved to start placing filter fabric and a crushed rock pad above.



Copy to: Steve Moore - Summit Homes
Summit Homes - Dale Hart
File

Continued
on next page